

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 7270-1130:160

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Honeywell Inc., 1500 West Dundee Road., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models T487A1003, T487A1011, T487B1002 and T487B1010. 136NF and 190NF fixed temperature and rate-of-rise. Suitable for explosion proof and outdoor use when installed with explosion proof box or weatherproof box. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature ratings and UL label.

APPROVAL: Listed as system heat detectors for use with separately listed compatible fire alarm control units.

XLF: 7270-0061:002

09-26-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager